



## **LEAD IN POTABLE WATER SCREENING REPORT**

---

**INVESTIGATION FOR:** Susan O Donnell  
Headstart Community Program of Morris County  
18 Thompson Avenue  
Dover, NJ 07801

**SITE INVESTIGATED:** Headstart Communtiy Program  
18 Thompson Avenue  
Dover, NJ 07801

**ASSESSMENT BY:** Rey Montes De Oca  
Omega Environmental Services, Inc.  
280 Huyler Street  
South Hackensack, NJ 07606

**INVESTIGATION  
CONDUCTED:** 2/6/18

**DATE OF REPORT:** 2/21/18

(Omega Project # 18-27002)

## **TABLE OF CONTENTS**

### **EXECUTIVE SUMMARY/PROJECT OVERVIEW**

- 1. RESULTS TABLE**
- 2. SAMPLING METHODOLOGY**
- 3. DISCUSSION OF RESULTS**
- 4. RECOMMENDATIONS**

#### Appendices:

A. Laboratory Analytical Reports

## **EXECUTIVE SUMMARY:**

The Headstart Community Program of Morris County requested lead in water testing of potable water outlets at the Headstart Communitiy Program on 18 Thompson Avenue, Dover, NJ 07801.

### *Previous Testing*

No information related to previous testing was available.

### *Recent Testing (2/6/18)*

In order to assess the building water outlets a full testing of all potable outlets was performed on February 6, 2018.

Reportedly the outlets were not flushed or used on the day of testing.

First draw and flush (30 seconds) samples were collected of 20 water fountains and sinks.

**All results were below the Lead and Copper action level of 15 ppb and 1,300 ppb respectively.**

See Section 3 Discussion of Results

# 1 RESULTS TABLE:

Sample #	Location	1 <sup>st</sup> draw (FD) and Flush (FL)	Lead Results (ppb)	LCR Action Level (1) (ppb)	Copper Results (ppb)	LCR Action Level (1) (ppb)
01	KC01 DW Sprayer	FD	1.04	15	17	1,300
01A	KC01 DW Sprayer	FL	NA	15	NA	1,300
02	KC02 Split Sink Left	FD	ND	15	22	1,300
02A	KC02 Split Sink Left	FL	NA	15	NA	1,300
03	KC03 Split Sink Right	FD	ND	15	47	1,300
03A	KC03 Split Sink Right	FL	NA	15	NA	1,300
04	KC04 Utility Sink	FD	ND	15	8.8	1,300
04A	KC04 Utility Sink	FL	NA	15	NA	1,300
05	TL05 Tech Lounge	FD	ND	15	47	1,300
05A	TL05 Tech Lounge	FL	NA	15	NA	1,300
06	RS06 Room 6 Left	FD	ND	15	14	1,300
06A	RS06 Room 6 Left	FL	NA	15	NA	1,300
07	RS07 Room 6 Right	FD	ND	15	16	1,300
07A	RS07 Room 6 Right	FL	NA	15	NA	1,300
08	RS08 Room 7 Teachers Sink	FD	ND	15	19	1,300
08A	RS08 Room 7 Teachers Sink	FL	NA	15	NA	1,300
09	RS09 Room 7 Left	FD	ND	15	20	1,300
09A	RS09 Room 7 Left	FL	NA	15	NA	1,300
10	WC10 Auditorium	FD	ND	15	550	1,300
10A	WC10 Auditorium	FL	NA	15	NA	1,300
11	RS11 Room 2 Left	FD	ND	15	140	1,300
11A	RS11 Room 2 Left	FL	NA	15	NA	1,300
12	RS12 Room 2 Right	FD	ND	15	170	1,300
12A	RS12 Room 2 Right	FL	NA	15	NA	1,300
13	RS13 Room 1 Left	FD	ND	15	230	1,300
13A	RS13 Room 1 Left	FL	NA	15	NA	1,300
14	RS14 Room 1 Right	FD	ND	15	280	1,300
14A	RS14 Room 1 Right	FL	NA	15	NA	1,300
15	RS15 Room 9 Left	FD	ND	15	180	1,300
15A	RS15 Room 9 Left	FL	NA	15	NA	1,300
16	RS16 Room 9 Right	FD	ND	15	540	1,300
16A	RS16 Room 9 Right	FL	NA	15	NA	1,300
17	RS17 Room 10 Left	FD	ND	15	610	1,300
17A	RS17 Room 10 Left	FL	NA	15	NA	1,300
18	RS18 Room 10 Right	FD	ND	15	630	1,300
18A	RS18 Room 10 Right	FL	NA	15	NA	1,300
19	RS19 Room 4 Left	FD	ND	15	22	1,300
19A	RS19 Room 4 Left	FL	NA	15	NA	1,300

20	RS20 Room 4 Right	FD	ND	15	26	1,300
20A	RS20 Room 4 Right	FL	NA	15	NA	1,300
FB	Field Blank	FD	ND	15	ND	1,300

<sup>(1)</sup> EPA Lead and Copper Rule (1991) Action Level for water suppliers (municipalities and private wells) and March 2016 Newark Public Schools Lead Water Testing Sampling Plan.

FD – First Draw Sample

FL – Flush Sample (30 sec)

ND – Indicates that the analyte was not detected at the reporting limit

NA – Not Analyzed

## 2 SAMPLING METHODOLOGY:

First Draw Samples - Without allowing any water to spill until sample collection, samples were collected with a relatively slow flow rate in 250 mL bottles prepared with Nitric Acid (HNO<sub>3</sub>) as a preservative.

Flush Samples – After collection of first draw samples the water was allowed to flow at a relatively slow rate for thirty second to flush the fixture and close piping. The flush samples are intended to test the plumbing further upstream from the fixture (behind walls).

The samples were packaged in a cooler and shipped to EMSL Analytical, Inc, Cinnaminson, NJ for total lead in potable water analysis (method E200.8 IOC).

## 3 DISCUSSION OF RESULTS:

**All lead in water results were below the EPA Lead and Copper action level.**

## 4 RECOMMENDATIONS:

*Short term:*

- No further action is recommended in regards to outlets test

*Long Term:*

- Repeat full building testing on an annual basis. Generally this should be performed in August prior to the start of the school season.
- Develop a Lead in Water Management Plan in accordance with the 2006 EPA 3Ts for Reducing Lead in Drinking Water in Schools.

## A. Lead in Water Laboratory Reports



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Michael Levay**  
**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**

2/21/2018

Phone: (201) 489-8700  
Fax: (201) 489-8797

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 2/7/2018. The results are tabulated on the attached data pages for the following client designated project:

**18-27002**

The reference number for these samples is EMSL Order #011800889. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011800889

CustomerID: OMEG50

CustomerPO:

ProjectID:

Attn: **Michael Levay**  
**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**

Phone: (201) 489-8700  
 Fax: (201) 489-8797  
 Received: 02/07/18 2:45 PM

Project: 18-27002

**Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
01 KC01 DW Sprayer FD					011800889-0001			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	17	5.0	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	1.04	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
02 KC02 Split Sink L FD					011800889-0003			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	22	5.0	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
03 KC03 Split Sink R FD					011800889-0005			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	47	5.0	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
04 KC04 Utility Sink FD					011800889-0007			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	8.8	5.0	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
05 TL05 Tech Lounge FD					011800889-0009			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	47	5.0	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
06 RS06 Room 6L FD					011800889-0011			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	14	5.0	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011800889  
 CustomerID: OMEG50  
 CustomerPO:  
 ProjectID:

Attn: **Michael Levay**  
**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**

Phone: (201) 489-8700  
 Fax: (201) 489-8797  
 Received: 02/07/18 2:45 PM

Project: 18-27002

**Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
07 RS07 Room 6R FD					011800889-0013			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	16	5.0	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
08 RS08 Room 7 Teachers Sink FD					011800889-0015			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	19	5.0	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
09 RS09 Room 7 L FD					011800889-0017			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	20	5.0	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
10 WC10 Auditorium FD					011800889-0019			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	550	50	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
11 RS11 Room 2L FD					011800889-0021			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	140	25	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
12 RS12 Room 2R FD					011800889-0023			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	170	25	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011800889  
 CustomerID: OMEG50  
 CustomerPO:  
 ProjectID:

Attn: **Michael Levay**  
**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**

Phone: (201) 489-8700  
 Fax: (201) 489-8797  
 Received: 02/07/18 2:45 PM

Project: 18-27002

**Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
13 RS13 Room 1 L FD					011800889-0025			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	230	25	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
14 RS14 Room 1 R FD					011800889-0027			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	280	25	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
15 RS15 Room 9 L FD					011800889-0029			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	180	25	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
16 RS16 Room 9 R FD					011800889-0031			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	540	50	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
17 RS17 Room 10L FD					011800889-0033			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	610	50	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM
<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
18 RS18 Room 10R FD					011800889-0035			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Copper	630	50	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011800889

CustomerID: OMEG50

CustomerPO:

ProjectID:

Attn: **Michael Levay**  
**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**

Phone: (201) 489-8700  
 Fax: (201) 489-8797  
 Received: 02/07/18 2:45 PM

Project: 18-27002

**Analytical Results**

**Client Sample Description** 19  
 RS19 Room 4L FD **Collected:** **Lab ID:** 011800889-0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Copper	22	5.0	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM

**Client Sample Description** 20  
 RS20 Room 4R FD **Collected:** **Lab ID:** 011800889-0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Copper	26	5.0	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM

**Client Sample Description** FB  
 Field Blank **Collected:** **Lab ID:** 011800889-0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Copper	ND	5.0	µg/L	2/14/2018	SM	2/14/2018	SM
200.8	Lead	ND	1.00	µg/L	2/14/2018	SM	2/14/2018	SM

**Definitions:**

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)



EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS TRAINING

### Lead (Pb) Chain of Custody

EMSL Order ID (Lab Use Only):

PHONE: ( )  
FAX: ( )

011800889

Company: OMEGA ENVIRONMENTAL SERVICES		EMSL-Bill to: <input checked="" type="checkbox"/> Same <input type="checkbox"/> Different <small>If Bill to is Different note instructions in Comments**</small>	
Street: 280 HUYLER STREET		<i>Third Party Billing requires written authorization from third party</i>	
City: SOUTH HACKENSACK	State/Province: NJ	Zip/Postal Code:	Country:
Report To (Name): MIKE LEVAY		Telephone #:	
Email Address: MIKEL@OMEGA-ENV.COM		Fax #:	Purchase Order:
Project Name/Number: 18-27002		Please Provide Results: <input type="checkbox"/> Fax <input type="checkbox"/> Email	
U.S. State Samples Taken: NEW JERSEY		CT Samples: <input type="checkbox"/> Commercial/Taxable <input type="checkbox"/> Residential/Tax Exempt	

**Turnaround Time (TAT) Options\* - Please Check**

<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 48 Hour	<input type="checkbox"/> 72 Hour	<input type="checkbox"/> 96 Hour	<input type="checkbox"/> 1 Week	<input checked="" type="checkbox"/> 2 Week
---------------------------------	---------------------------------	----------------------------------	----------------------------------	----------------------------------	----------------------------------	---------------------------------	--

\*Analysis completed in accordance with EMSL's Terms and Conditions located in the Price Guide

Matrix	Method	Instrument	Reporting Limit	Check
Chips <input type="checkbox"/> % by wt. <input type="checkbox"/> mg/cm <sup>2</sup> <input type="checkbox"/> ppm (mg/kg)	SW846-7000B	Flame Atomic Absorption	0.01%	<input type="checkbox"/>
Air	NIOSH 7082	Flame Atomic Absorption	4 µg/filter	<input type="checkbox"/>
	NIOSH 7105	Graphite Furnace AA	0.03 µg/filter	<input type="checkbox"/>
	NIOSH 7300M/NIOSH 7303	ICP-OES	0.5 µg/filter	<input type="checkbox"/>
Wipe* <span style="float: right;">ASTM <input type="checkbox"/> non ASTM <input type="checkbox"/></span> <small>*if no box checked, non-ASTM Wipe assumed</small>	SW846-7000B	Flame Atomic Absorption	10 µg/wipe	<input type="checkbox"/>
	SW846-6010B or C	ICP-OES	1.0 µg/wipe	<input type="checkbox"/>
TCLP	SW846-1311/7000B/SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW846-1311/SW846-6010B or C	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
SPLP	SW846-1312/7000B/SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW846-1312/SW846-6010B or C	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
TTLC	22 CCR App. II, 7000B/7420	Flame Atomic Absorption	40 mg/kg (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW846-6010B or C	ICP-OES	2 mg/kg (ppm)	<input type="checkbox"/>
STLC	22 CCR App. II, 7000B/7420	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW846-6010B or C	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
Soil	SW846-7000B	Flame Atomic Absorption	40 mg/kg (ppm)	<input type="checkbox"/>
	SW846-6010B or C	ICP-OES	2 mg/kg (ppm)	<input type="checkbox"/>
Wastewater <span style="float: right;">Unpreserved <input type="checkbox"/> Preserved with HNO<sub>3</sub> pH &lt; 2 <input type="checkbox"/></span>	SM3111B/SW846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	<input type="checkbox"/>
Drinking Water <span style="float: right;">Unpreserved <input type="checkbox"/> Preserved with HNO<sub>3</sub> pH &lt; 2 <input checked="" type="checkbox"/></span>	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	<input checked="" type="checkbox"/>
	EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)	<input type="checkbox"/>
	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	<input type="checkbox"/>
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	<input type="checkbox"/>
	40 CFR Part 50	Graphite Furnace AA	3.6 µg/filter	<input type="checkbox"/>
Other:				<input type="checkbox"/>

Name of Sampler: REY MONTES DE OCA Signature of Sampler:

Sample #	Location	Volume/Area	Date/Time Sampled
01	KC01 DW SPRAYER FD	250ml	6:30 2/6/18
01A	KC01 DW SPRAYER FL	250ml	6:32 2/6/18

Client Sample #s: - Total # of Samples: 4

Relinquished (Client): Rey Montes de la Date: 2/6/18 Time: 11:30

Received (Lab): \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

Comments: PLEASE ANALYZE FOR COPPER AND LEAD  
**ONLY ANALYZE FLUSH IF FD IS LARGER THAN 15 PPM!**

CPCOCC: Y 7:20P 2/6/18



EMSL ANALYTICAL, INC.  
LABORATORY PRODUCTS • TRAINING

### LEAD (Pb) CHAIN OF CUSTODY

EMSL ORDER ID (Lab Use Only):

011800889

PHONE: ( )

FAX: ( )

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Sample #	Location	Volume/Area	Date/Time Sampled
3 02	KC02 SPLIT SINK L FD	250ml	6:40 2/6/18
4 02A	KC02 SPLIT SINK L FL	250ml	6:42 2/6/18
5 03	KC03 SPLIT SINK R FD	250ml	6:45 2/6/18
6 03A	KC03 SPLIT SINK R FL	250ml	6:50 2/6/18
7 04	KC04 UTILITY SINK FD	250ml	7:00 2/6/18
8 04A	KC04 UTILITY SINK FL	250ml	7:02 2/6/18
9 05	TL05 TECH LOUNGE FD	250ml	7:10 2/6/18
10 05A	TL05 TECH LOUNGE FL	250ml	7:12 2/6/18
11 06	RS06 ROOM 6L FD	250ml	7:20 2/6/18
12 06A	RS06 ROOM 6L FL	250ml	7:22 2/6/18
13 07	RS07 ROOM 6R FD	250ml	7:24 2/6/18
14 07A	RS07 ROOM 6R FL	250ml	7:26 2/6/18
15 08	RS08 ROOM 7 TEACHERS SINK FD	250ml	7:35 2/6/18
16 08A	RS08 ROOM 7 TEACHERS SINK FL	250ml	7:38 2/6/18
17 09	RS09 ROOM 7 L FD	250ml	7:40 2/6/18
19 09A	RS09 ROOM 7 L FL	250ml	7:42 2/6/18
19 10	WC10 AUDITORIUM FD	250ml	8:00 2/6/18
20 10A	WC10 AUDITORIUM FL	250ml	8:02 2/6/18
<b>Comments/Special Instructions:</b> PLEASE ANALYZE FOR COPPER AND LEAD			

Page 2 of 4 pages

EMSL ANALYTICAL, INC.  
LABORATORY • PRODUCTS • TRAINING**LEAD (Pb) CHAIN OF CUSTODY**

EMSL ORDER ID (Lab Use Only):

011800889

PHONE: ( )

FAX: ( )

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Sample #	Location	Volume/Area	Date/Time Sampled
21 11	RS11 ROOM 2L FD	250ml	8:15 2/6/18
22 11A	RS11 ROOM 2L FL	250ml	8:18 2/6/18
23 12	RS12 ROOM 2R FD	250ml	8:20 2/6/18
24 12A	RS12 ROOM 2R FL	250ml	8:22 2/6/18
25 13	RS13 ROOM 1 L FD	250ml	8:27 2/6/18
26 13A	RS13 ROOM 1 L FL	250ml	8:30 2/6/18
27 14	RS14 ROOM 1 R FD	250ml	8:32 2/6/18
28 14A	RS14 ROOM 1 R FL	250ml	8:35 2/6/18
29 15	RS15 ROOM 9 L FD	250ml	8:45 2/6/18
30 15A	RS15 ROOM 9 L FL	250ml	8:47 2/6/18
31 16	RS16 ROOM 9 R FD	250ml	8:50 2/6/18
32 16A	RS16 ROOM 9 R FL	250ml	8:52 2/6/18
33 17	RS17 ROOM 10L FD	250ml	9:01 2/6/18
34 17A	RS17 ROOM 10L FL	250ml	9:03 2/6/18
35 18	RS18 ROOM 10R FD	250ml	9:05 2/6/18
36 18A	RS18 ROOM 10R FL	250ml	9:07 2/6/18
37 19	RS19 ROOM 4L FD	250ml	9:10 2/6/18
38 19A	RS19 ROOM 4L FL	250ml	9:12 2/6/18

Comments/Special Instructions:

PLEASE ANALYZE FOR COPPER AND LEAD

Page 3 of 4 pages

